



DECLARATION

Issued	31-08-2018	Scope	---
Report	2002888	Page	1 of 2
PIN	0476CT2888		

Kiwa Cermet Italia hereby attests that the central heating boilers:

Trade mark:

BERETTA

Logo



Models:

*as specified in the **Annex 1***

are covered by the the essential requirements as described in the **Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

Appliance type: B_{11BS}

Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Related to the following gas groups: *as specified in the **Annex 1***

The assessment tests have been performed using the following standard as guidelines:
EN 15502-1:2012+A1:2015, EN 15502-2-2:2014

The present declaration doesn't substitute the EC certificate nr. KIP-15917/G
This declaration is valid until withdrawal or replacement of the above mentioned EC certificate

Industry Division Manager
Maurizio Lorenzon

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC



DECLARATION

Issued 31-08-2018 Scope ---
Report 2002888 Page 2 of 2
PIN 0476CT2888

ANNEX 1

Models

Mynute 28 C.A.I. Lx, Meteo 24 C.A.I. Lx, Meteo 28 C.A.I. Lx
are approved for following gas groups

Group	mbar
E	20

Group	mbar
H	20;25

Group	mbar
P	37;50

Models

Mynute 24 C.A.I. Lx, Ciao 24 C.A.I. Lx, Quadra II 24 C.A.I. Lx
are approved for following gas groups

Group	mbar
E	20
Lw	20

Group	mbar
H	20;25
Ls	13

Group	mbar
P	37;50

The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC



Number KIP-15917/E Replaces ---
 Issued 31-08-2018 Scope Directive 92/42/EEC
 Regulation (EU) No. 813/2013
 Report 2002888 Page 2 of 3
 PIN 0476CT2888

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Models:

	Mynute 24 C.A.I. Lx, Ciao 24 C.A.I. Lx, Quadra II 24 C.A.I. Lx	Mynute 28 C.A.I. Lx
η_{100}	90,1 %	90,5 %
η_{30}	89,2 %	89,5 %
η_4	81,1 %	81,5 %
η_1	80,3 %	80,6 %
P_4	24,1 kW	28,9 kW
P_1	7,1 kW	8,6 kW
C.Heater?	Yes	Yes
B ₁ Boiler?	Yes	Yes
Type of boiler:	Other	Other

	Meteo 24 C.A.I. Lx	Meteo 28 C.A.I. Lx
η_{100}	90,1 %	90,3 %
η_{30}	89,5 %	89,2 %
η_4	81,1 %	81,3 %
η_1	80,6 %	80,3 %
P_4	24,1 kW	28,8 kW
P_1	7,2 kW	8,5 kW
C.Heater?	Yes	Yes
B ₁ Boiler?	Yes	Yes
Type of boiler:	Other	Other

CERTIFICATE

Kiwa Cermet Italia S.p.A.
 Società con socio unico, soggetta all'attività di
 direzione e coordinamento di Kiwa Italia
 Holding Srl

Via Cadriano, 23
 40057 Granarolo dell'Emilia (BO)

Unità locale
 Via Treviso 32/34
 31020 San Vendemiano (TV)

Tel +39. 0438 411755
 Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it



Number	KIP-15917/E	Replaces	---
Issued	31-08-2018	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2002888	Page	3 of 3
PIN	0476CT2888		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 2

Note:

η_{100} = At rated heat output and high-temperature regime - NCV (*)

η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**)

η_4 = At rated heat output and high-temperature regime - GCV (*)

η_1 = At 30 % of rated heat output and low-temperature regime - GCV (**)

P_4 = At rated heat output and high-temperature regime (*)

P_1 = At 30 % of rated heat output and low-temperature regime (**)

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = B₁ according CEN/TR 1749:2014

Type of boiler = "Condensig Boiler" or "Low Temperature Boiler" or Other Boiler"

Efficiency's values have been measured with gas G20.

(n.t.= not tested)

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadrano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it